

# CVPCSD Monthly Report

May 2024

Daily average flow = 312 gpm

Daily Average Raw NTU = 3.87

Daily Average Finished NTU = 0.021

## Water Plant –

- Tried to repair crack in applied channel with non shrink grout. Did not fix the issue. Will have to have a specialist come out.
- Wildfire insurance audit with Do. I was not present. Sounds like we need to cut down a bunch of trees near plant, tank site and access road.
- PCWA swapped out meter chamber for our main meter.
- Harry had to disassemble and clean then reassemble poly pump. Parastaltic tube ruptured inside pump.
- 

## Distribution –

- Repaired leak for customer at 4245 ponderex.
- Turned off water for repair at 6017 Kenneth
- 

## Summary

- Fairly quiet month. Will mostly catch up streaming current project this next month.
- Will monitor sludge that is drying to get ready for removal.
- Will start digging up services in June for Lead Service Line Inventory.
- Will complete CCR for 2024 in June. Needs to be on website by July 1<sup>st</sup>.