

# CVPCSD Monthly Report

JANUARY 2025

Daily average flow = 186 gpm

Daily Average Raw NTU = 5.36

Daily Average Finished NTU = .023

## Water Plant –

- Standard operations, ie chemical top offs, adjustments to treatment etc.
- Plant treated very well during the storm
- 3<sup>rd</sup> and 4<sup>th</sup> quarter drought reports were not completed, so in the process of completing those and should have them done by the end of the week
- Lead Inventory Report required updating. Its been submitted and awaiting approval

## Distribution –

- Ordered meters for replacement at 11 locations. Our plan was to begin replacing the first week of February until the series of storms hit. Will be starting as soon as the weather clears up a bit
- Replaced two curb stops on Gregg Wy
- Leak reported at meter/backflow on Stanley. Replaced the 90 that split
- Fixed gasket leak on Christian valley road

## Summary

- Very smooth transition. No unusual issues at the plant.
- We will order a truck load of gravel pack to put at the plant in the case of a major leak so we can at least shut down the affected area and cover any holes in the roadway until repairs can be made.
- We would like to replace a check valve at the plant, \$2-3k replacement per Gerry LaBudde who would like to be involved.
- Clamps and saddles and misc part repair – working on taking inventory and will advise what we should have in stock for minor repairs.
- Drum Double containment from USA Bluebook. This is instead of the previously approved plan and will be significantly cheaper, in the neighborhood of \$1000