

CVPCSD Monthly Report

June 2024

Daily average flow = 406 gpm

Daily Average Raw NTU = 1.8

Daily Average Finished NTU = .026

Water Plant –

- New plant computer/firewall is in process. Tim ran into a couple issues and had to abort install. Install scheduled for Monday 7/8/24
- Installed Ice machine at water plant to have ice for ice chest for sampling, and for drinking water jugs (safety).
- Leak on post hypo tank fitting. Lost some chemical in tank. Harry repaired. I think we should just buy all three chem tanks with containment this year (pre/post hypochlorite, poly)
- Had a second hypo leak resulting in more chemical leaked this week.
- Working with PCAPCD for permitting the generator that was replaced and permitting the existing generator at the water plant.
- -

Distribution –

- Very quiet in distribution this month.
- Monthly samples
- Starting valve exercising and backflow testing next month
- Starting lead service line inspections after July 4th

Summary

- CCR completed for 2023 and uploaded to SWRCB, and CVP website.