

# CVPCSD Monthly Report

APRIL 2026

Daily average flow = 250 gpm

Daily Average Raw NTU = 3.7

Daily Average Finished NTU = .02

## Water Plant –

- Standard operations, ie chemical top offs, adjustments to treatment etc.
- Spring Cleaning still underway. Weed whacking around the plant and storage tank and additional up near a trail at 5168 West Ridge Cr
- Due to a lack of time, could Harry outsource moving the shed as he keeps thinking he will have time to work on it, but basic maintenance is taking up too much time.

## Distribution

- Leak repaired on Mary by Lorang Brothers. 1.25" had a hole in the side of it. Pipe buried with rock and no sand. We would propose replacing from Mary & Thomas to about half way down the hill as LaBudde recently replaced from about half way down the hill to the bottom. I have spoken to Lorang Brothers who will get a quote together.
- 2599 Allen Dr – Service line leak. Provided assistance to resident in turning off the water
- 2305 Christian Valley Rd – Leak at the curb stop. Minor leak at this time. Working on hiring assistant to assist Harry with some of these repairs

## Summary

- Attempted to locate the pipe at Ross and Williams with a locator. We were unable to locate.
- After speaking with Gerry LaBudde, he is not confident ground penetrating radar will work. Gerry suggests a witcher.
- Harry advising the tank and plant areas are getting a little overgrown with fresh tree growth. Does CVP have a tree trimming company they use? 49er has a guy that works on spring sites and Nestle Waters is very happy with his work.
- Harry also advising the WTP buildings could use a fresh coat of paint as they are starting to peel in places.