

CVPCSD Monthly Report

December 2024

Daily average flow = 197 gpm

Daily Average Raw NTU = 4.46

Daily Average Finished NTU = .022

Water Plant –

- Standard maintenance.
- Had a couple storm related callouts. Nothing major.
- Installed new brushes on floc mixer motor #2.

Distribution –

- Completed Backflow testing
- Finished Meter changes

Summary

- Wrap up our operations for transfer to 49er Lab.
- Gave plant site visit to customer
- Need to swap water quality sampling location from Helen to across the street to Patrick