CVPCSD Monthly Report

October 2026

Daily average flow = 354 gpm

Daily Average Raw NTU = 12.1

Daily Average Finished NTU = .02

Water Plant –

- Standard operations, ie chemical top offs, adjustments to treatment etc.

Distribution

- 5235 Pondorex – Resident needed assistance shutting off water for a service line break
  3223 Christian Valley Rd – Resident reported a lot of water coming out of the ground in her horse pasture. Turned out to be a main break for a main that has always been a little bit of a mystery in terms of location. Saddle came loose to the service line across the street. Section of pipe removed by Lorang and replaced.

Summary

- Everything is running great despite a lot of plant upsets due to the much higher turbidity in the raw water. Flows are slightly down from last month.
- Air Compressor failed for upper system. The compressor has a life time warranty but has failed 3 times now. Charlie suggested a different type of compressor that should have a much longer life. The failed compressor was replaced free of charge and is on site as a backup.
- Harry would like to discuss some upcoming maintenance that will be required along with clean up at the plant and possibly construction of new shelving in the lab area. Removal and possible replacement of the desk on site which is beginning to fall apart